

# UNT AGL SECONDARY POWER – C

**SEKONDER PİST AYDINLATMA KABLOSU – TİP C**  
**SECONDARY AIRPORT LIGHTING CABLE – TYPE C**

**UNE 21123-2 /FAA – L 824**  
**( AC - 150/5375-7E SPECIFICATION FOR L-824)**

## KABLO YAPISI

- \* İLETKEN : İnce çok telli Tavlı Bakır İletken (Tip TC ) veya İnce çok telli Kalaylı (Tip BC) Bakır İletken
- \* İZOLE : XLPE
- \* DIŞ KILIF : Polyethylene (PE), PVC veya Halojensiz (HF) malzeme

## CABLE STRUCTURE

- \* CONDUCTOR : Fine Strand of annealed tinned copper wires (Type TC ) or fine plain copper wires (Type BC )
- \* INSULATION : XLPE
- \* OUTER JACKET : PE, PVC or HF material



## ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 600 V
- TEST GERİLİMİ / TEST VOLTAGE : 2 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 10 x Outer Diameter
- TEST STANDARDI / STANDARD OF TEST : UNE 21123-2/FAA – L 824 AC - 150/5375-7E

Tüm kesitler AWG ve Metrik olarak sağlanabilir.  
All sizes are available in AWG and Metric